

**ADDENDUM 1  
TO THE CONTRACT PROVISIONS AND CONTRACT PLANS**

**FOR**

**CITY OF RIDGEFIELD  
JUNCTION BOOSTER STATION VFD UPGRADE**

**G&O #19273**

**ISSUED THIS DATE: WEDNESDAY, MARCH 11, 2020**

**BID OPENING: 4:00 P.M. (LOCAL TIME) ON  
WEDNESDAY, MARCH 18, 2020  
CITY OF RIDGEFIELD  
230 PIONEER STREET  
RIDGEFIELD, WASHINGTON 98642**



**Bidder shall acknowledge receipt of this Addendum on Page 14 of the Proposal.**

---

TO PROSPECTIVE BIDDERS:

The attention of all prospective bidders on the above project is directed to the following additions and modifications to the Contract Provisions and Contract Plans.

**I. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE TECHNICAL SPECIFICATIONS**

**ITEM 1:**

Page 11210-2, Technical Specification Section 11210-2.1, PUMP

**REVISE** the subsection B. as shown below (added text is italicized, deleted text is shown as strike out):

- "B. Pump Construction.
  - a. Volute Cast Iron
  - b. Shaft Steel
  - c. Impeller ~~Bronze~~ *Stainless Steel*"